

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AG5212

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product.

D.P. Garg & Co. Pvt. Ltd Range of Mortice Locks See Annex A

Intended use: For use on fire/smoke compartmentation doors.

Essential characteristics	Performance	Harmonised technical specification
Mechanical test evidence: WIL 371136, WIL 371533, WIL 416730, WIL 416731, WIL 416760 & WIL 419136 Fire test evidence: WF 376740, WF 376741 & WF 377588 iss.9		
Self-closing 5.4.2 Closing force	Grade 4 = 100kg door mass with 25N maximum closing force	EN 12209:2003 / AC:2005
5.1.2 Re-latching force of latch bolt	>2.5N	
Durability of self-closing 5.3.1 Durability of latch action	Grade M = 200,000 cycles with 25N side load on latch bolt.	
Ability to maintain the door in the closed position and not contribute to its spread of fire	Grade 1: 2kN	
5.2.1 Resistance to side load on latch bolt		
5.5 Suitability for use on fire/smoke doors	Grade 1: suitable for use on fire/smoke resistant door assemblies	
Dangerous substances	Pass: the materials in the lock do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AG5212

Placed on the market under the name of:

**D.P. Garg & Co. Pvt. Ltd.
B-210B, Phase-2
Noida-201305
Gautam Budh Nagar
(U.P.) India**

and produced in the manufacturing plant

E000323-1

This is coded format, and the information is held by the Notified Body.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard:

EN 12209:2003 / AC:2005

Under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **16/10/2020** and re-issued on **21/12/2023** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: **20/12/2026**

ERO Project Reference: **ERO 034621 P2015**



Pascal Coget
General Manager - European Certification

CSF408-NL 8.0

Certificate of Constancy of Performance

2812-CPR-AG5212

Annex A

Model No	Description	Backset	Centres
LAL1727	2.5" Euro / Oval Profile Mortice Sash Lock Body	45mm	47.5mm
LAL1728	3" Euro / Oval Profile Mortice Sash Lock Body	58mm	47.5mm
LAL1535	2.5" Arch. Bathroom Lock Body	45mm	57mm
LAL1536	3" Arch. Bathroom Lock Body	58mm	57mm
LAL1438	2.5" Mortice Bathroom Lock Body (T-3N)	45mm	58mm

Forends available in the following finishes:

ANT	Antique	MBZ	Matt bronze
ABR	Antique brass	MSB	Matt satin brass
ABZ	Antique bronze	MEB	Mirror electro brass
0AC	Antique copper	ONP	Nickel plated
BNP	Black nickel	ORB	Oil rub bronze
BZP	Bright zinc plated	0PB	Polished brass
0CP	Chrome plated	PCP	Polished chrome plated
DBR	Dull electro brass	PNP	Polished nickel plated
DXB	Durosil epoxy black	PSS	Polished stainless steel / mirror
DSL	Durosil silver	RGL	Rose gold
0EB	Electro brass	SBR	Satin brass
EXB	Epoxy black	SCP	Satin chrome plated
EXW	Epoxy white	SNP	Satin nickel plated
0FB	Florentine bronze	0SS	Satin stainless steel
GAL	Galvorite	SLV	Silver
GSL	Galvorite silver	SSS	Simulated satin finish
0GN	Graphite nickel	OUB	Urban bronze
MBN	Gun metal	UDB	Urban dark bronze
MAB	Matt antique brass	USC	Urban satin copper
OMB	Matt black		

Brand names:

GARG, GARGS, TUFF, ELITE, SICHERN