

Approved body No. 1121

Certificate of constancy of performance 1121-CPR-UK-AG7869

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

DP Garg & Co. Pvt. Ltd Range of Mortice Locks - See Annex A

Intended use:

For use on fire/smoke compartmentation doors

Essential characteristics	Performance	Harmonised technical specification
	Mechanical test evidence: WIL419136, 416730, 416760 & 371533 Fire test evidence: WF 377588	
Self-closing 5.4.2 Closing force	Grade 4 = 100kg door mass with 25N maximum closing force	
5.1.2 Re-latching force of latch bolt	>2.5N	
Durability of self-closing 5.3.1 Durability of latch action	Grade M = 200,000 cycles with 25N side load on latch bolt.	
Ability to maintain the door in the closed position and not contribute to its spread of fire	Grade 1	EN 12209: 2003/AC 2005
Control of Dangerous substances	If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the lock do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	



Certificate of constancy of performance

1121-CPR-UK-AG7869

Placed on the market under the name of

D P Garg & Co. Pvt. Ltd B- 210b, Phase- 2, Noida - 201 305

and produced in the manufacturing plant

R/001

This is coded format and the information is held by the Approved Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 12209:2003/AC 2005

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 10/08/2021 and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

Valid to: 09/08/2024

Paul Duggan Certification Manager

UK FA

Warringtonfire Testing and Certification Limited Holmesfield Road, Warrington, Cheshire, WA1 2DS, UK

Page 2 of 3



Certificate of constancy of performance 1121-CPR-UK-AG7869

Annex A

Product	Size 2.5"	Model Reference LAL1727
EURO / OVAL PROFILE MORTISE SASH LOCK BODY		
EURO / OVAL PROFILE MORTISE SASH LOCK BODY	3"	LAL1728
ARCH. BATHROOM LOCK BODY	2.5"	LAL1535
ARCH. BATHROOM LOCK BODY	3"	LAL1536
MORTISE BATHROOM LOCK BODY (T-3N)	2.5"	LAL1438

All the above products are available in the following finishes & brand names:

Finishes: PSS, SSS, EB, MEB, NI, CP, PCP, SNI, SCP, BNI, SEN, AB, ACu, ABr, EXW, EXB, RG, SRG, PL1, PL2, Arj, Durosil & DuroBlk.

Brand names: ECLIPSE, GARG, GARGS, TUFF, ELITE, SICHERN, BASIC, BASICS, ESSENTIAL, JUPITER, MARS, EXCEL, FIRESTOP, UNIFIX, CENTURION, ASEC, ASEC VITAL, TUFFITE, EUROSTAR, XL, SHEILD & I-CE.